

Shower area



- Shower floor area flush with surrounding floor, without steps or impediments to walking or wheelchairs, anti-slip floor. Later installation of a bathtub should be possible.
- Space for movement at least 120 cm x 120 cm for DIN 18025/2, otherwise at least 150 cm x 150 cm.
- Folding shower seat fixed firmly in place or able to be firmly attached, seat height 46 cm - 48 cm, seat depth minimum 45 cm.
- Support rails on both sides 28 cm over seat height, 65 cm - 70 cm between rails, rails at least 15 cm longer than front of seat.
- Grab rail and tap at height of 85 cm, operable with one hand and water temperature limited to maximum 45 °C.

